



WEATHERPROOF DISCHARGE.
COMPLETE WITH VERMIN PROOF MESH.

CPEF.01
CAR PARK EXHAUST FAN
MOUNTED ON SKID FRAMES.
550x550 EXHAUST RISER FROM
BELOW TURNS AT ROOF LEVEL TO
IN-LINE EXHAUST FAN COMPLETE
WITH WEATHERPROOF DISCHARGE.

450x400 KITCHEN EXHAUST RISER
FROM BELOW TURNING AT ROOF
LEVEL TO TERMINATE AT ROOF
LEVEL FOR FUTURE CONNECTION
BY OTHERS. PROVIDE CAPPING TO
DUCTWORK ENDS.

4-OFF OUTDOOR CONDENSING UNITS
SERVING PENTHOUSE APARTMENTS ON
LEVEL 4 BELOW.

GEF.01
ROOF MOUNTED GENERAL EXHAUST FAN
SERVING WASTE ROOM ON GROUND
FLOOR BELOW.

REFRIGERANT PIPWORK TO DROP IN
SINGLE ROOF PENETRATION TO LEVEL
4 BELOW.

TOILET EXHAUST ROOF COWL,
CONNECT TO 350x350 EXHAUST AIR
RISER FROM BELOW, TYPICAL.

KITCHEN EXHAUST ROOF COWL,
CONNECT TO 350x350 EXHAUST AIR
RISER FROM BELOW, TYPICAL.

TO BE PRINTED IN COLOUR

THE PURPOSE OF THIS DOCUMENT IS INTENDED TO BE
VIEWED OR PRINTED IN COLOUR FOR THE FULL EXTENT OF
THE SCOPE OF WORKS TO BE SHOWN.

A	CONSTRUCTION ISSUE	21.09.18	HW
REV/N	DESCRIPTION	DATE	CHKD

LUCID
CONSULTING AUSTRALIA
Level 3/169, Pirie St Adelaide SA 5000
Phone: (08) 8407 9700
Email: adelaide@lucidconsulting.com.au



PROJECT
THE WILLCOX APARTMENTS
117 PROSPECT ROAD, PROSPECT

DRAWING
ROOF LEVEL AIR CONDITIONING AND
VENTILATION ARRANGEMENT

MECHANICAL SERVICES

SCALE 1 : 100 @ A1	DATE SEPTEMBER 2018	DESIGNED TR	DRAWN DG	No. IN SET 8 OF 9
DRAWING NUMBER LCE13523-M08	REVISION A			