



REFER DRAWING S00 FOR GENERAL NOTES

- WALL PANEL NOTES:
- WALL PANELS TO BE 150 THICK UNO. (25mm MAX. GROOVE DEPTH) SL102 CENTRAL + N20 EDGE BARS CENTRAL (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
 - WALL PANELS TO BE 175 THICK UNO. (25mm MAX. GROOVE DEPTH) SL92 EACH FACE (UNO) + N16 EDGE BARS EACH FACE (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
 - WALL PANELS TO BE 200 THICK UNO. (25mm MAX. GROOVE DEPTH) SL102 EACH FACE (UNO) + N16 EDGE BARS EACH FACE (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
 - LIFT/STAIR CORE WALL PANELS TO BE 200 THICK UNO. (25mm MAX. GROOVE DEPTH) SL81 EACH FACE + N16 EDGE BARS EACH FACE (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
 - REFER TO WALL PANEL ELEVATIONS & DETAILS FOR DOWEL FIXINGS.
 - CONFIRM PANEL SIZES WITH PRECAST CONTRACTOR, THE ENGINEER IS TO BE NOTIFIED IF PANEL SIZES ARE TO BE ADJUSTED.
 - REINFORCEMENT SPECIFIED IS FOR "IN POSITION" LOADING ONLY. THE MANUFACTURER IS TO PROVIDE ANY ADDITIONAL REINFORCEMENT IF REQUIRED FOR CASTING, TRANSPORTATION, LIFTING, ERECTION ETC.
 - REFER TO ARCHITECTURAL DRAWINGS FOR ANY ARCHITECTURAL FEATURES, PENETRATIONS, DP'S ETC.
 - REFER TO SECTIONS & ELEVATIONS FOR ADDITIONAL REINFORCEMENT.
 - ENSURE APPROPRIATE COVER TO CAST IN PLATE LUGS AT GROOVE LOCATIONS THE ENGINEER IS TO BE NOTIFIED IF SUCH CLASHING OCCURS.
 - PENETRATIONS IN WALL PANELS FOR SERVICES ARE TO BE CONSTRUCTED DURING CASTING OF WALL PANELS.
 - ALL FERRULES TO BE RAMSET ROUND FERRULES x 96mm LONG WITH N12 x 300 LONG BACKING ROD UNO.
 - PROVIDE MINIMUM CLEAR COVER OF 35mm TO ALL REINFORCEMENT.
 - PROVIDE 'XYPEX' OR SIMILAR APPROVED MOISTURE PROOFING ADDITIVE TO ALL WALL PANELS RETAINING SOIL, TO MANUFACTURERS SPECIFIC

LEGEND

- G.P1 150 DENOTES 150 THICK WALL PANEL TYPE
- G.P1 175 DENOTES 175 THICK WALL PANEL TYPE
- G.P1 200 DENOTES 200 THICK WALL PANEL TYPE
- G.CP1 200 DENOTES 200 THICK LIFT/STAIR CORE WALL PANEL TYPE
- G.BP1 175 DENOTES 175 THICK BALCONY WALL PANEL TYPE
- G.NP1 XX DENOTES NON-LOAD BEARING WALL PANEL TYPE
- CC DENOTES CORNER PANEL CONNECTION REFER TO DETAILS
- SC DENOTES SUSPENDED WALL PANEL CONNECTION REFER TO DETAILS
- SCC DENOTES SUSPENDED CORNER PANEL CONNECTION REFER TO DETAILS

GROUND FLOOR WALL PANEL PLAN
1:100

BASEMENT FLOOR WALL PANEL PLAN
1:100

AA	FOR CONSTRUCTION	DG	FK	19.10.18
No	REVISION	DRAWN	CHE'KD	DATE

PROJECT

THE WILLCOX APARTMENTS
AT: 117 PROSPECT ROAD
PROSPECT, SA 5082
FOR: CITIFY & BFC PTY LTD

DRAWING TITLE

CONCRETE WALL PLANS - BASEMENT & GROUND

Civil	Structural
Environmental	Geotechnical
Mechanical	Electrical
Fire	Hydraulics
Lifts	Green ESD

Level 6, 100 Pirie Street,
Adelaide SA 5000
Telephone 08 8238 4100
Facsimile 08 8410 1405

TMK
CONCRETE SOLUTIONS

SCALES	AS SHOWN	© COPYRIGHT RESERVED
DRAWN	DG	DRAWING No.
DATE	APRIL 2018	1802052-S300/AA
ENGINEER	FK	
CHECKED		

0 10 20 30 40 50 100mm
When sheet printed full size, the scale bar is 100mm.