

Reference: TRIM

28-Jun-2016

Tanunda Property Trust - FUA Pty Ltd
11 Indama St
REGENCY PARK SA 5010

Dear Sir / Madam

Waste Water System Application No.: WWS/122/2016/ALTER
Owner: FUA Pty Ltd
Description: Application for Alteration
to existing CWMS
Wastewater System -
Grease Trap
Subject Land: Shop 5, 46-48 Murray
Street, TANUNDA

Further to your Wastewater System Application above, you are hereby advised that a decision on the application has been made by Council.

A copy of the Approval for a Wastewater System is attached for your information.

You are advised that:

- (1) **One (1) business day notice to Council, is required for the compulsory inspection of underfloor plumbing and associated works. All pipes and fittings are required to be water tested.**
- (2) **Where the effluent disposal from the premises will require a gravity connection to Council's CWMS (Community Wastewater Management Scheme), it is the applicant's responsibility to check the depth of the CWMS connection point to ensure that the connection by gravity drainage can be achieved.**

Please contact the undersigned if you require further assistance on 8563 8444.

Yours faithfully,



Karen Bandt
Environmental Health Officer

