



REFER DRAWING S00 FOR GENERAL NOTES

WALL PANEL NOTES:

- 1. WALL PANELS TO BE 100 THICK UNO. (25mm MAX. GROOVE DEPTH) SL82 CENTRAL + N16 EDGE BARS CENTRAL (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
- 2. WALL PANELS TO BE 150 THICK UNO. (25mm MAX. GROOVE DEPTH) SL102 CENTRAL + N20 EDGE BARS CENTRAL (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
- 3. WALL PANELS TO BE 175 THICK UNO. (25mm MAX. GROOVE DEPTH) SL92 EACH FACE (UNO) + N16 EDGE BARS EACH FACE (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
- 4. WALL PANELS TO BE 200 THICK UNO. (25mm MAX. GROOVE DEPTH) SL102 EACH FACE (UNO) + N16 EDGE BARS EACH FACE (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
- 5. LIFT/STAIR CORE WALL PANELS TO BE 200 THICK UNO. (25mm MAX. GROOVE DEPTH) SL81 EACH FACE + N16 EDGE BARS EACH FACE (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
- 6. REFER TO WALL PANEL ELEVATIONS & DETAILS FOR DOWEL FIXINGS.
- 7. CONFIRM PANEL SIZES WITH PRECAST CONTRACTOR, THE ENGINEER IS TO BE NOTIFIED IF PANEL SIZES ARE TO BE ADJUSTED.
- 8. REINFORCEMENT SPECIFIED IS FOR 'IN POSITION' LOADING ONLY. THE MANUFACT' IS TO PROVIDE ANY ADDITIONAL REQ' IF REQUIRED FOR CASTING, TRANSPORTATION, LIFTING, ERECTION ETC.
- 9. REFER TO ARCHITECTURAL DRAWINGS FOR ANY ARCH' FEATURES, PENETRATIONS, DP'S ETC.
- 10. REFER TO SECTIONS & ELEVATIONS FOR ADDITIONAL REINFORCEMENT.
- 11. ENSURE APPROPRIATE COVER TO CAST IN PLATE LUGS AT GROOVE LOCATIONS THE ENGINEER IS TO BE NOTIFIED IF SUCH CLASHING OCCURS.
- 12. PENETRATIONS IN WALL PANELS FOR SERVICES ARE TO BE CONSTRUCTED DURING CASTING OF WALL PANELS.
- 13. ALL FERRULES TO BE RAMSET ROUND FERRULES x 96mm LONG WITH N12 x 300 LONG BACKING ROD UNO.
- 14. PROVIDE MINIMUM CLEAR COVER OF 35mm TO ALL REINFORCEMENT.
- 15. PROVIDE 'XYPEX' OR SIMILAR APPROVED MOISTURE PROOFING ADDITIVE TO ALL WALL PANELS RETAINING SOIL, TO MANUFACTURERS SPEC'

LEGEND

- 1P1 150 DENOTES 150 THICK WALL PANEL TYPE
- 1P1 175 DENOTES 175 THICK WALL PANEL TYPE
- 1P1 200 DENOTES 200 THICK WALL PANEL TYPE
- 1CP1 200 DENOTES 200 THICK LIFT/STAIR CORE WALL PANEL TYPE
- 1BP1 175 DENOTES 175 THICK BALCONY WALL PANEL TYPE
- 1NP1 XX DENOTES NON-LOAD BEARING WALL PANEL TYPE
- CC DENOTES CORNER PANEL CONNECTION  
REFER TO DETAILS
- SC DENOTES SUSPENDED WALL PANEL CONNECTION  
REFER TO DETAILS
- SCC DENOTES SUSPENDED CORNER PANEL CONNECTION  
REFER TO DETAILS

LEVEL 1 FLOOR WALL PANEL PLAN  
1:100

AB	AS NOTED	DG	FK	13.12.18
AA	FOR CONSTRUCTION	DG	FK	19.10.18
No	REVISION	DRAWN	CHE'KD	DATE

PROJECT  
THE WILLCOX APARTMENTS  
AT: 117 PROSPECT ROAD  
PROSPECT, SA 5082  
FOR: CITIFY & BFC PTY LTD

DRAWING TITLE  
CONCRETE WALL PLAN - LEVEL 1

Civil  
Environmental  
Mechanical  
Fire  
Lifts

Structural  
Geotechnical  
Electrical  
Hydraulics  
Green ESD

Level 6, 100 Pirie Street,  
Adelaide SA 5000  
Telephone 08 8238 4100  
Facsimile 08 8410 1405

  
TMA  
CONCRETE DESIGN

SCALES AS SHOWN	© COPYRIGHT RESERVED
DRAWN DATE ENGINEER CHECKED	DRAWING No. 1802052-S301/AB

